

Estacada School District Retest Results and Follow Up

| Sample name / Location | LEAD TEST 6/13/16 | ACTION TAKEN | RETEST COLD 8/3/16 FIRST/FLUSH | RETEST HOT 8/3/16 FIRST/FLUSH | ACTION TAKEN | RETEST RESULTS 9/2/16 | RETEST RESULTS 9/16/16 | ACTION TAKEN |
|------------------------------|----------------------|--------------------|--------------------------------------|-------------------------------------|------------------|-----------------------------|------------------------------|-----------------|
| Estacada High School | | | | | | | | |
| 81. Metal staff bathroom | 241 | retested | 51.2 / 5.1 | 8.8 | New fixture/line | 3.2 | | |
| 87. Auto Custodial | 19.3 | Not retested | | | | | | |
| 88. Auto Girls Bathroom | 24.6 | retested | 17.6 | 4.1 | | | 7 / .3 | |
| 90. Auto Outside Faucet | 16.1 | retested | 4.7 | no hot | OK | | | |
| 91. Room 11 #1 | 252 | DC (decomissioned) | | | | | | |
| 92. Room 11 #2 | 2210 | DC | | | | | | |
| 93. Room 11 #3 | 202 | DC | | | | | | |
| 94. Room 11 #4 | 314 | DC | | | | | | |
| 95. Room 11 #5 | 17.8 | DC | | | | | | |
| 97. Room 11 Podium | 195 | retested | 21.9 / 67.7 | 61.7 / 3.1 | DC | | | |
| Room 12 Podium | N/A | tested | 51 / 3.5 | 406 / 160 | DC | | | |
| 99. Room 12 #2 | 15.7 | DC | | | | | | |
| 100. Room 12 #3 | 19.6 | DC | | | | | | |
| 101. Room 12 #4 | 1300 | DC | | | | | | |
| 102. Room 12 #5 | 47.1 | DC | | | | | | |
| 105. Room 10 #1 | 202 | DC | | | | | | |
| 106. Room 10 #2 | 180 | DC | | | | | | |
| 107. Room 10 #3 | 44.4 | DC | | | | | | |
| 109. Room 10 #5 | 309 | DC | | | | | | |
| 110. Room 10 #6 | 33.8 | DC | | | | | | |
| 111. Room 10 Podium | 25.4 | retested | 28.8 / 3.6 | 52.9 / 1.4 | DC | | | |
| 113. Room 10 Storage #2 Cage | 1790 | DC | | | | | | |
| 115. Room 13 #1 Front Sink | 42.4 | retested | 41 / 5.8 | 12.4 | New fixture/line | 1 | | |
| 116. Room 13 #2 | 10.2 | retested | 16.2 | 5.3 | New fixture/line | 0.7 | | |
| 117. Room 13 #3 | 176 | retested | | | New fixture/line | 1 | | |
| 118. Room 13 #4 | 48.4 | retested | 32.6 / 1.2 | 36 / 1.9 | New fixture/line | 1 | | |
| 119. Room 13 #5 | 17.8 | retested | | | New fixture/line | 4 | | |

Estacada School District Retest Results and Follow Up

| Sample name / Location | LEAD TEST 6/13/16 | ACTION TAKEN | RETEST COLD 8/3/16 FIRST/FLUSH | RETEST HOT 8/3/16 FIRST/FLUSH | ACTION TAKEN | RETEST RESULTS 9/2/16 | RETEST RESULTS 9/16/16 | ACTION TAKEN |
|-----------------------------------|----------------------|-------------------|--------------------------------------|-------------------------------------|------------------|-----------------------------|------------------------------|-----------------|
| 120. Room 13 #6 | 64.5 | retested | 34.3 / 3.6 | 9.3 | New fixture/line | 2.7 | | |
| 121. Room 13 #7 | 32.8 | retested | | | New fixture/line | 2.2 | | |
| 122. Room 13 #8 | 7.3 | retested | 31.1 / 1.5 | 10.7 | New fixture/line | 3.2 | | |
| 124. Room 13 Front Wash | 21.2 | retested | 17 | N/A | | | | |
| 128. Room 15 #1 Front South | 72.1 | DC | | | New fixture/line | 16.1 | 3.3 / .4 | OK |
| 130. Room 15 #1 Back South | 286 | DC | | | New fixture/line | 22.4 | 5 / .4 | OK |
| 131. Room 15 #1 Back North | 166 | DC | | | DC | | | |
| 132. Room 15 #2 Front East | 6,170 | DC | | | DC | | | |
| 133. Room 15 #2 Front West | 240 | DC | | | New fixture/line | 65.5 | 19 / 1.9 | DC |
| 134. Room 15 #2 Back East | 1,530 | DC | | | New fixture/line | 30.1 | 12 / 1.1 | OK |
| 135. Room 15 #2 Back West | 456 | DC | | | DC | | | |
| 136. Room 15 #3 Front South | 432 | DC | | | DC | | | |
| 137. Room 15 #3 Front South | 108 | DC | | | New fixture/line | 58.8 | 11.1 / 1.1 | OK |
| 138. Room 15 #3 Back North | 256 | DC | | | New fixture/line | 20.7 | 22.7 / .9 | DC |
| 139. Room 15 #3 Back South | 569 | DC | | | DC | | | |
| 140. Room 15 Podium East | 431 | DC | | | DC | | | |
| 141. Room 15 Podium West | 283 | retested | 24.8 / 61.7 | 135 / 5.8 | DC | | | |
| 142. Room 15 Storage Wash | 426 | retested | 542 / 5.8 | 108 / 12.3 | New fixture/line | 0.6 | | |
| 144. Room 9 #2 (back sink) | 9.5 | retested | 4.3 | 0.8 | OK | | | |
| 150. Room 19 Faucet | 26.1 | retested | 20.8 / 4.7 | 82.6 / 6.0 | New fixture | 7.4 | | |
| 160. Room 6 #2 | 38.6 | new fixture/retes | 0.2 | 0.2 | | | | |
| 161. Room 6 #3 | 17.8 | retested | 23.7 / .5 | 26.6 / 3.8 | New fixture | 6.4 | | |
| 173. Kitchen Bath | 18.8 | retested | 7.1 | 0.2 | OK | | | |
| 182. Student Store - mixer faucet | 30.6 | retested | 4.9 | | OK | | | |
| 185. Girls Locker East Bath | 25.6 | retested | 10.3 | 1.8 | OK | | | |
| 186. Girls Locker West Bath | 16 | retested | 47.9 / 1.2 | 19.2 | New fixture | 4.7 | | |
| 189. Mens Locker West Bath | 23.9 | retested | 27.9 / .8 | 18.4 | New fixture | 18.6 | 4.3/2.0 H .6/. | OK |
| 196. G6 Drinking | 45.7 | retested | 8.2 | N/A | OK | | | |

Estacada School District Retest Results and Follow Up

| Sample name / Location | LEAD TEST 6/13/16 | ACTION TAKEN | RETEST COLD 8/3/16 FIRST/FLUSH | RETEST HOT 8/3/16 FIRST/FLUSH | ACTION TAKEN | RETEST RESULTS 9/2/16 | RETEST RESULTS 9/16/16 | ACTION TAKEN |
|--|----------------------|-----------------------|--------------------------------------|-------------------------------------|----------------|-----------------------------|------------------------------|-----------------|
| 199. G 6 coach | 71.7 | retested | 58.8 / 7.1 | 48 / 8.2 | New fixture | 21.4 | 5.3 / 8.0 | OK |
| 201. G 9 #1 | 20.4 | retested | 79.1 / 25.7 | 31.6 / 21.8 | DC | | | |
| 201. COLD recommissioned | | | | | Recommissioned | | .8 / .2 | OK |
| 201. HOT recommissioned | | | | | Recommissioned | | .7 / .3 | OK |
| 202. G9 #2 | 20.7 | retested | 9.4 | 17.6 | | C .5 / .3 H 1.3 / | | OK |
| 203. G9 Coach | 51.2 | retested | 23.3 / 2.9 | N/A | New fixture | 10.5 | | |
| EHS-SPA-97 - outdoor spigot baseball diamond | | not previously tested | 80.8 / 3.3 | N/A | New fixture | 1.8 | | |
| Clackamas River School | | | | | | | | |
| 314. A pod #3 CRE-SCA-01 Staff B | 39.5 | New fixture | 0.5 | | OK | | 1.2 / .3 | OK |
| 314. A Pod #3 CRE SHA-03 Staff B | 39.5 | New fixture | | 0.5 | OK | | .4 / .5 | OK |
| 314D. CRS-314DFA/B-01/02 | | | | | | | .2 / ND | OK |
| 350. Nurse bath | 15 | | | | | | 0.7 | OK |
| Middle School | | | | | | | | |
| 239. Room 110 #7 | 16.6 | | | | | | 26.9 / 7.6 | DC |
| River Mill Elementary | | | | | | | | |
| 7. South Hall boys #4 | 14.7 | | | | | | 6.5 | OK |
| 11. Kitchen North Sink | 536 | | | | | | 4.6 | OK |
| 12. Kitchen soup faucet | n/a | | | | | C 10.4/5.4 H 1.8/ | | OK |
| 16. Room 1 Drinking | 224 | | | | | | 5.8 / .8 | OK |
| 22. Room 4 Drinking | 25.5 | | | | | | 6.1 / 2 | OK |
| 23. Room 4 Faucet | 42.9 | | | | | | 12.7 / 1.1 | OK |
| 29. Room 5 Drinking | 17.8 | | | | | | 4.2 / 1.3 | OK |
| 30. Room 5 Faucet | 29.9 | | | | | | .9 / 1 | OK |
| 36. Room 17 Drinking | 18.4 | | | | | | 21.5 / 1.9 | DC |
| 37. Room 17 Faucet | 28 | | | | | | 2.8 (tested 9/2) | OK |
| 43. Room 15 Drinking | 19.7 | | | | | | 2.9 / 1.1 | OK |
| 52. Room 11 Drinking | 14.5 | | | | | | 1.2 / 2.4 | OK |
| 56. Room 9 Drinking | 16.6 | | | | | | 12.1 / 1.4 | OK |

Estacada School District Retest Results and Follow Up

| Sample name / Location | LEAD TEST 6/13/16 | ACTION TAKEN | RETEST COLD 8/3/16 FIRST/FLUSH | RETEST HOT 8/3/16 FIRST/FLUSH | ACTION TAKEN | RETEST RESULTS 9/2/16 | RETEST RESULTS 9/16/16 | ACTION TAKEN |
|-------------------------------|-------------------------|-------------------------|--------------------------------------|-------------------------------------|--------------|-----------------------------|------------------------------|-----------------|
| 57. Room 9 Faucet | 60 | | | | | | 1.3 (tested 9/2) | OK |
| 58. Room 8 Drinking | 14.5 | | | | | | 2 / 5.5 | OK |
| STADIUM COMPLEX | Test Results 8/25/16 | ACTION TAKEN | xxx | xxxx | xxxxxx | xxxxxxx | Retest Results 9/16/16 | Action Taken |
| ESDS-BSCA-05/Girls bath right | 45.6 | New fixture/line | | | | | 4.3 / 1.9 | OK |
| ESDS-BSCB-06/Girls bath right | 6 | Hot decommissioned | | | | | N/A | |
| ESDS-BSCA-07/Girls bath mid | 54.3 | New fixture/line | | | | | 6.6 / 1.4 | OK |
| ESDS-BSCB-08/Girls bath mid | 13.1 | Hot decommissioned | | | | | N/A | |
| ESDS-BSCA-09/Girls bath left | 5.6 | New fixture/line | | | | | 3.0 / .9 | OK |
| ESDS-BSCB-10/Girls bath left | 111 | Hot decommissioned | | | | | N/A | |
| ESDS-BSCA-11/Boys bath right | 23.8 | New fixture/line | | | | | 2.7 / .8 | OK |
| ESDS-BSCB-12/Boys bath right | 3.3 | Hot decommissioned | | | | | N/A | |
| ESDS-BSCA-13/Boys bath mid | 4.2 | New fixture/line | | | | | Not tested | |
| ESDS-BSCB-14/Boys bath mid | 1.3 | Hot decommissioned | | | | | Not tested | |
| ESDS-BSCA-15/Boys bath left | 65 | New fixture/line | | | | | 2.8 / 1.1 | OK |
| ESDS-BSCA-160/ Boys bath left | not tested | Hot decommissioned | | | | | N/A | |